

Certificate of Compliance

Certificate Number:

EX1216

Report Reference:

EX1216-20190306
EX1216-20250529

Issue Date:

2025-OCT-14

Issued to:

Manufacturer:

Fire & Hazard Control Equipment Co. Ltd.

69th Street, P.O. Box 8401,

Dammam II Industrial Area

Dammam 31482, Saudi Arabia

Listee:

Ansul- A Tyco Fire Protection Products Brand

1 Stanton St., Marinette, WI. 54143-2542

This certificate confirms that representative samples of:

Dry-Chemical Extinguishers, Hand and Wheeled

See Addendum for Model Information

Has been evaluated by UL LLC in accordance with Standard(s) for Safety:

UL 299, Dry Chemical Fire Extinguishers

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch

UL Mark Certification Program Owner



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

Certificate of Compliance

Certificate Number: EX1216
Report Reference: EX1216-20190306
EX1216-20250529
Issue Date: 2025-OCT-14

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Nominal Agent Capacity, lb (kg)	Min Use Temp, °F (°C)	Class A Rating	Class B Rating	Class C Rating	Marine Type
Ammonium phosphate						
A-10-G-1	8.5 (3.86)	-40 (-40)	4-A	40-B	Yes	Yes
A-20-G-1	17.0 (7.71)	-40 (-40)	6-A	60-B	Yes	Yes
A-30-G-1	25.0 (11.30)	-40 (-40)	10-A	80-B	Yes	Yes
Potassium bicarbonate						
K-10-G	9.0 (4.08)	-40 (-40)	-	60-B	Yes	Yes
K-20-G	18.0 (8.16)	-40 (-40)	-	80-B	Yes	Yes
K-30-G	27.0 (12.30)	-40 (-40)	-	120-B	Yes	Yes

Cont. on next page--

Certificate of Compliance

Certificate Number: EX1216
Report Reference: EX1216-20190306
 EX1216-20250529
Issue Date: 2025-OCT-14

Model	Nominal Agent Capacity, lb. (kg)	Min Use Temp, °F (°C)	Class A Rating	Class B Rating	Class C Rating	Marine Type
Ammonium phosphate						
CR-I-A-150-C-1	125 (57)	-40 (-40)	30-A	160-B	Yes	Yes
CR-I-A-150-D-1	125 (57)	-40 (-40)	30-A	240-B	Yes	Yes
Potassium Bicarbonate						
CR-I-K-150-C	125 (57)	-40 (-40)	-	320-B	Yes	Yes
CR-LR-I-K-150-C	125 (57)	-40 (-40)	-	80-B	Yes	Yes
CR-I-K-150-D	125 (57)	-40 (-40)	-	320-B	Yes	Yes

The following optional prefixes apply to the indicated extinguisher types and models:

Prefix	Construction feature	Extinguisher Types
CR	Corrosion resistant paint and components	C Series Wheeled, D Series Wheeled
I	Pressure indicator in the fill cap	C Series Wheeled, D Series Wheeled
LR	Long range nozzle	C Series Wheeled, D Series Wheeled
RT	Rubber tires	C Series Wheeled, D Series Wheeled
WW	Wide wheels	C Series Wheeled, D Series Wheeled
MIL	Military use	C Series Wheeled, D Series Wheeled
CP	Chrome plated	C Series Wheeled, D Series Wheeled
LT	Low temperature range (-65°F)	C Series Wheeled, D Series Wheeled