

Certificate of Compliance

Certificate Number(s):

UL-US-26113138-0

Report Reference:

EX15719-20260413

Issue Date:

2026-04-14

Issued to:

Fire & Hazard Control Equipment Co Ltd
69th Street, P.O. Box 8401, Dammam II Industrial Area, Dammam,
31482, SA

This certificate confirms that representative samples of:

GAQF - Clean-agent Extinguishing System Units

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

ANSI/CAN/UL/ULC 2166, 3rd Ed, Issue Date: 2017-5-10, Revision
Date: 2021-12-8

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-26113138-0
Report reference: EX15719-20260413
Issue Date: 2026-04-14

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Engineered, Halocarbon

Model(s): FHC Easy Flow, FM-200/HFC-227ea engineered extinguishing system units, 25 bar

Clean Agent Extinguishing System Units		Value
Extinguishing Agent (ASHRAE Designation)		HFC-227ea
Manuals and Bulletins		
Part No.	Description	Date/Rev
FHCM-EFSPFS-02	Installation and Design manual	May 2025
System Unit Information		
Operating Pressure at Temperature	Minimum Operating Temperature	Maximum Operating Temperature
25 bar at 21 °C	32 F (0 C)	130 F (54.4 C)
These installations require the use of the Listee's flow calculation software:		
FHC4.00		

Engineered, Halocarbon

Model(s): FHC Piston Flow, FM-200/HFC-227ea engineered extinguishing system units, 25 bar

Clean Agent Extinguishing System Units		Value
Extinguishing Agent (ASHRAE Designation)		HFC-227ea
Manuals and Bulletins		
Part No.	Description	Date/Rev
FHCM-EFSPFS-02	Installation and Design manual	May 2025
System Unit Information		
Operating Pressure at Temperature	Minimum Operating Temperature	Maximum Operating Temperature
25 bar at 21 °C	32 F (0 C)	130 F (54.4 C)
These installations require the use of the Listee's flow calculation software:		
FHC4.00		

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

